

Rule 12.5 Inspection Port Technical Completion Requirement

All wells shall be equipped with a watertight sanitary well seal with a ½" or larger interior diameter inspection port, located on top of the well seal which allows for free access to the water table for the purpose of water level measurement and disinfection. Any well presently not equipped shall in the future be so equipped when that well is serviced. On those wells with odd sized casing, which cannot be fitted with a factory made watertight sanitary well seal, the completion must be done in a manner that will prevent any pollutants (waste, insects, chemicals, etc.) from entering the well.